

Exova Warringtonfire
Holmesfield Road
Warrington
WA1 2DS
United Kingdom

T : +44 (0) 1925 655 116
F : +44 (0) 1925 655 419
E : warrington@exova.com
W: www.exova.com



Testing. Advising. Assuring.

Title:

CLASSIFICATION OF
REACTION TO FIRE
PERFORMANCE
IN ACCORDANCE WITH
EN 13501-1:2007+A1: 2009.

Notified Body No:

0833

Product Name:

"FL Multi"

Report No:

WF 403803

Issue No:

2

Prepared for:

Brick Development
Association,
The Building Centre,
26 Store Street,
London,
WC1E 7BT

Date:

23rd August 2018



1. Introduction

This classification report defines the classification assigned to "FL Multi", a fired clay brick, in accordance with the procedures given in EN 13501-1:2007+A1:2009

2. Details of classified product

2.1 General

The product, "FL Multi", a fired clay brick, is defined as being suitable for construction applications.

2.2 Product description

The product, "FL Multi", is fully described below and in the test reports provided in support of classification listed in Clause 3.1.

Generic type	Fired clay brick
Product reference	"FL Multi"
Name of manufacturer	Michelmersh
Density	1460kg/m ³
Thickness	65mm
Colour	"Red"
Flame retardant details	See Note 1 Below
Brief description of manufacturing process	Shaped, dried and fired

Note 1: The sponsor of the test has confirmed that no flame retardants were used in the production of this component.

3. Test reports & test results in support of classification

3.1 Test reports

Name of Laboratory	Name of sponsor	Test reports/extended application report Nos.	Test method / extended application rules & date
Exova Warringtonfire	Brick Development Association	WF 402885	BS EN ISO 1182
Exova Warringtonfire	Brick Development Association	WF 402886	EN ISO 1716

3.2 Test results

Test method & test number	Parameter	No. tests	Results	
			Continuous parameter - mean (m)	Compliance parameters
EN ISO 1182	Furnace Thermocouple Temperature Rise	5	3.2	Compliant
	Duration of Sustained Flaming		Nil	Compliant
	Mass Loss		0.12	Compliant
EN ISO 1716	For the product as a whole - PCS	3	0.1810 MJ/Kg	Compliant

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with clause 8 of EN 13501-1:2007+A1:2009.

4.2 Classification

The product, "FL Multi" a fired clay brick, in relation to its reaction to fire behaviour is classified:

A1, A1_{FL}, A1_L

The format of the reaction to fire classification for construction products is:

Reaction to fire classification: A1, A1_{FL}, A1_L

4.3 Field of application


This classification is valid for the following end use applications:

- i) Construction Applications

This classification is also valid for the following product parameters:

Product thickness	Any
Product composition	No variation allowed


SIGNED



.....
Katie Williams

Junior Certification Engineer
Technical Department

APPROVED



.....
Janet Murrell

Technical Manager
Technical Department
on behalf of **Exova Warringtonfire**

This copy has been produced from a .pdf format electronic file that has been provided by **Exova Warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Exova Warringtonfire**. The pdf copy supplied is the sole authentic version of this document. All pdf versions of this report bear authentic signatures of the responsible **Exova Warringtonfire** staff.

Issue 2: 28th August 2018, amendment to manufacturing process description. K.Williams